



TRANSMITTAL SHEET

Date sent: Thursday, June 14, 2018

Sent to: All Planholders

Deliver to: Project Estimator

Transmission sent from: Reichhardt & Ebe Engineering

Number of pages including this page: 3

CONFIRMATION OF RECEIPT OF ADDENDUM

PROJECT: City of Lynden Riverview Rd. Gap Elimination

Please complete the following form and email back to Reichhardt & Ebe Engineering, Inc. at officeadmin@recivil.com as soon as possible.

Have you received Addendum No. 1 for the above-mentioned project?

YES, we received Addendum No. 1

Signed: _____ Dated: _____

Company name (Please Print): _____

ADDENDUM NO. 1
To the Contract Provisions for
City of Lynden, Washington

RIVERVIEW RD. GAP ELIMINATION
City of Lynden Project No. 2013-04
Federal Aid No. STPUS-8162(001)

To the attention of all bidders for the above project:

Please find the following Addendum No. 1 for the above referenced project.

This addendum is to be considered as much a part of the Contract Documents as if it were included in the body of the plans and specifications, and will be incorporated in and made a part of the contract when awarded and when formally executed.

SPECIAL PROVISIONS

Item 1

The first line of Section 1-08.5 on Page 150 is revised to read:

This project shall be physically completed within *** 75 *** working days.

PROJECT CLARIFICATIONS

Item 2

There are 2 Puget Sound Energy plans sheets included in the Plans (Sheets 20 and 21). These plans sheets are noted as pages 1/3 and 2/3 respectively. Puget Sound Energy sheet 3 (page 3/3) is a sheet showing illumination calculations for the proposed street lighting that will be installed by Puget Sound Energy. The plan sheet was purposely omitted from the Riverview Rd. Gap Elimination Plans as it has no impact on the Work to be performed by the Contractor.

Item 3

Appendix F includes a summary of groundwater level measurements from two sites directly west of the project. The ground water measurements do not reference an existing ground elevation to determine and approximate depth below ground surface of the groundwater. The existing ground elevations are as follows:

- Well B-2 = 58.34
- South Well = 52.77

ADDENDUM NO. 1
To the Contract Provisions for
City of Lynden, Washington

END OF ADDENDUM NO. 1

Acknowledgement that this addendum has been received is required on the Bid Proposal, page 26.

Sincerely,



Ian Hinton, P.E.
Project Engineer